



GREEN MOUNTAIN POWER
GENERATION RESOURCE SYSTEM UPGRADE RIDER

All Generation Resources that apply under PUC Rule 5.504(B) to connect to circuits identified by GMP that have had transmission ground-fault overvoltage upgrades completed after July 1, 2019 and all others that have not yet had TGFOV mitigation are required to contribute to the cost of these GMP upgrades prior to interconnection. The fee shall be \$37/kW of installed AC capacity.

Any other upgrades that are identified as a result of review or system impact study will continue to be borne by the Generation Resource consistent with PUC Rule 5.500, as a part of the System Upgrade costs (exclusive of the transmission ground-fault overvoltage upgrade charge).